


- SPECIFIC NOTES:**
- 1 MOUNT RECEPTACLE IN THE ELEVATOR PIT.
  - 2 NOT USED.
  - 3 APPROXIMATE LOCATION OF THE SECOND FLOOR ELECTRICAL ROOM 164 ABOVE.
  - 4 CONNECT THE ELEVATOR PIT RECEPTACLE TO THE LINE SIDE OF THE LIGHT SWITCH LOCATED IN THE ELEVATOR PIT. SEE THE GROUND FLOOR LIGHTING PLAN, SHEET E2.1 FOR CONTINUATION.
  - 5 APPROXIMATE LOCATION OF THE MAIN ELECTRICAL ROOM 135 ON THE SECOND FLOOR ABOVE.
  - 6 APPROXIMATE LOCATION OF THE ELECTRICAL ROOM 168 ON THE SECOND FLOOR ABOVE.
  - 7 APPROXIMATE LOCATION OF THE ELECTRICAL ROOM 144 ON THE SECOND FLOOR ABOVE.
  - 8 MOUNT JUNCTION BOXES AT 48" A.F.F., UNLESS OTHERWISE NOTED.
  - 9 PROVIDE SUITABLE BACK BOX FOR HANDICAP PUSH PAD.
  - 10 TYPICAL MOTOR OPERATED DOOR.

- GENERAL NOTES:**
- 1.) FEED ALL COLUMN MOUNTED RECEPTACLES OVERHEAD VIA JUNCTION BOX. DO NOT RUN CONDUIT(S) UNDER GROUND.
  - 2.) MOUNT ALL COLUMN MOUNTED RECEPTACLES AT 48" A.F.F., UNLESS OTHERWISE NOTED.

1 GROUND FLOOR POWER PLAN  
SCALE: 1/16" = 1'-0"



NEW PHOENIX PRE-K THROUGH 12 SCHOOL

GROUND FLOOR POWER PLAN

**ASSOCIATED DESIGN GROUP, Inc.**  
CONSULTING ENGINEERS

**CORPORATE OFFICE**  
114 Toledo Drive  
Lafayette, Louisiana 70508  
(337) 234-8710

**NEW ORLEANS BRANCH**  
1010 Commons St.  
Suite 2405  
New Orleans, LA 70112  
(504) 581-8333

Project # 09193

ADDENDUM 2  
ATTACHMENT 48

DRAWN: JAM, ABF  
CHECKED: RAG  
SCALE:  
DATE: 05-24-2010

E2.6